

Versión 1.1

- Primera versión.

Versión 1.5

- Mejoras en el algoritmo de deshumectación: se deshumecta considerando la consigna de humedad absoluta en modo confort.

Versión 1.6

- Mejoras en el algoritmo de deshumectación

Versión 1.7

- Se añaden parámetros para el envío periódico de los objetos de control, y para establecer un tiempo mínimo entre el envío de esos objetos
- Se puede parametrizar el estado de la máquina cuando la habitación es ocupada sin estar vendida
- Configurar una histéresis de temperatura 0 para un modo especial desactiva la deshumectación en ese modo.

Version 1.1

- Initial version.

Version 1.5

- Improvements in the dehumidification algorithm: dehumidification is performed considering the absolute humidity setpoint in comfort mode.

Version 1.6

- Improvements in the dehumidification algorithm

Version 1.7

- New parameters for the periodic sending of control objects, and for setting a minimum time between the sending of these objects
- Possibility to configure the state of the climate unit when the room is occupied without being sold
- Setting a temperature hysteresis 0 for a special mode disables dehumidification in that mode.